



διανομή αερίου
αττικής
ΕΤΑΙΡΕΙΑ ΔΙΑΝΟΜΗΣ ΑΕΡΙΟΥ ΑΤΤΙΚΗΣ Α.Ε.

ΤΕΧΝΙΚΗ ΠΡΟΔΙΑΓΡΑΦΗ

ΕΔΑ- ΜΡ-003/0

M/R STATIONS WARNING LABELS

ΣΗΜΑΝΣΗ ΣΤΑΘΜΩΝ Μ/Ρ

ΣΥΝΤΑΞΗ:
ΤΜΗΜΑ ΤΕΧΝΙΚΗΣ
ΥΠΟΣΤΗΡΙΞΗΣ

ΕΓΚΡΙΣΗ:
ΕΠΙΤΡΟΠΗ
ΠΡΟΔΙΑΓΡΑΦΩΝ
ΕΔΑ ΑΤΤΙΚΗΣ
ΕΠΙΤΡΟΠΗ

ΕΠΙΤΡΟΠΗ ΤΕΧΝΙΚΗΣ
ΔΙΕΥΘΥΝΣΗΣ
ΕΔΑ ΑΤΤΙΚΗΣ

ΗΜΕΡΟΜΗΝΙΑ:

29/4/2004

ΑΝΑΘΕΩΡΗΣΗ 0

ΣΕΛΙΔΕΣ

4

TABLE OF CONTENTS

1. SCOPE
2. M/R STATIONS PROTECTED BY FENCING
3. M/R STATIONS NOT PROTECTED BY FENCING
4. DRAWINGS

1. Scope

This specification refers to the major industrial and distribution stations.

Two cases are distinguished:

- Stations with fencing
- Stations without fencing

2. Stations with fencing


The following warning labels shall be installed:

- a. A label (A1), with typical A3 dimensions, made from 1 mm thick aluminium plate, shall be placed on the outside face of the fence(see drawing 1, Point A1). EDA Attiki logo and emergency phones (11322, 8001111330) shall be written on the label.
- b. A waterproof plastic label (A2), with dimensions 20x20 cm, warning that the use of naked flame is not allowed, shall be installed at the front face of the station (see drawing 1).
- c. A second plastic label (A2 *) shall be installed at the front face of the station (next to the above mentioned one), warning that the use of mobile phones is not allowed (see drawing 1).
- d. A label (A3) , made from 1 mm thick aluminium plate , with dimensions 20x25 cm, shall be installed at A3 (see drawing 1). The label shall contain the following text: “the entrance without licence is not allowed” («ΑΠΑΓΟΡΕΥΕΤΑΙ Η ΕΙΣΟΔΟΣ ΣΤΟΥΣ ΜΗ ΕΧΟΝΤΕΣ ΕΡΓΑΣΙΑ»)


3. Stations without fencing:

B1: A waterproof, A₄(dimensions), plastic label, shall be installed at the front face and the back face of the station (B1, see drawing 2). EDA Attiki logo and emergency phones (11322, 8001111330) shall be written on the label.

4. DRAWINGS



Drawing 1: Position of the warning label when the M/R Station is protected by fencing



Drawing 2: Position of the warning label when the M/R Station is not protected by fencing