

INDICATING LABELS FOR SERVICE VALVES

ΠΙΝΑΚΙΔΕΣ ΣΗΜΑΝΣΗΣ ΠΑΡΟΧΕΤΕΥΤΙΚΩΝ ΒΑΝΩΝ

| | | |
|--|---|------------------------------|
| ΣΥΝΤΑΞΗ: ΤΜΗΜΑ ΤΕΧΝΙΚΗΣ ΥΠΟΣΤΗΡΙΞΗΣ | ΕΓΚΡΙΣΗ: ΕΠΙΤΡΟΠΗ ΠΡΟΔΙΑΓΡΑΦΩΝ ΕΔΑ ΑΤΤΙΚΗΣ ΕΠΙΤΡΟΠΗ ΤΕΧΝΙΚΗΣ ΔΙΕΥΘΥΝΣΗΣ ΕΔΑ ΑΤΤΙΚΗΣ | ΗΜΕΡΟΜΗΝΙΑ: 28/4/2004 |
| | ΑΝΑΘΕΩΡΗΣΗ 0 | ΣΕΛΙΔΕΣ 4 |

TABLE OF CONTENTS

1. SCOPE
2. MATERIAL AND DIMENSIONS
3. INSTALLATION GUIDELINES
4. DRAWING

1. Scope

This specification describes the marking labels that are used to indicate the position of the service isolating valve. The label shall be placed on the property wall, at the vertical axis of the service line, in order to indicate the location of the service valve, even if the latter is covered (in example by an asphalt layer or a parked car)

2. Material and dimensions:

Material: the material of the indicating labels for the network

Dimensions: diameter 100mm

Thickness: 5mm

Color: Yellow

Diameter of the central hole: 7mm

3. Installation guidelines:

If the distance between property wall and service valve is longer than one meter, this distance shall be recorded on the label.

4. Drawings (attached page)

